

TRADE WASTE AND EFFLUENTS RESEARCH UNIT (REGIONAL LAB) PATIALA

Room No. 303, 2nd Floor, Water Supply & Sanitation Department, Head Office, Nabha Road, Patiala
researchunitpatiala@yahoo.in

TEST REPORT			
Name & Address of Customer : St. Xavier's International School, Vill- Attalan, Patran.		Customer Reference No.	No. 115 Dated : 28/04/2026
		Sample Submitted by	
		Date of Sample Receipt	30/04/2026
		Analysis Starting Date	30/04/2026
		Analysis completion Date	05/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No. :		Sample Type :	Water
Test Report No.:	TWERU/2627/00083	Date of Issue :	05/05/2026
Registration no.:	TWERU/REG2627/00326	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Ro at St. Xavier's International School, Attalan, Patran. / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Patiala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Colour	<2	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Brij Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, Trade Waste and Effluents Research Unit
(Regional Lab) Patiala

----- End of the Test Report -----